

Number	25-002279-PR08 (NW-A01-02-en-01)
Owner	Kontinent-Group LLC Nebesnoji Sotni Str. 18002 Cherkasy Ukraine
Product	Tilt and turn window
Designation	System: F 46M Shipping name: FRAMEX
Details	Manufacturer Kontinent-Group LLC, - Cherkasy; Material Aluminium; Type of opening Tilt and turn; Opening direction DIN right, inward opening; Overall dimensions (W x H) 900 mm x 2200 mm
Special features	Position of lockings

Result **)


Air permeability according to EN 12207:2016-12

**Class: 2**

Resistance to wind load according to EN 12210:2016-03

**Class: C3/B3**

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim
15.09.2025
Robert Kolacny, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Component Testing
Maximilian Denkl
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09

*) and corresponding national versions
(e.g. DIN EN)Test report: 25-002279-PR08 PB-
A01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift-Test Documents" applies.

Identity-Check

www.ift-rosenheim.de/ift-geprueft
ID: FCD-B2F98