

Classification Report

Number	25-002279-PR02 (NW-A01-02-en-01)	Basis *) EN 14351-1:2006+A2:2016-09 *) and corresponding national versions (e.g. DIN EN)
Owner	Kontinent-Group LLC Nebesnoji Sotni Str. 18002 Cherkasy Ukraine	Test report: 25-002279-PR02 PB-A01-02-en-01
Product	Sliding door	Representation
Designation	System: SL 3000	
Details	Shipping name: FRAMEX Sliding door Manufacturer Kontinent-Group LLC, - Cherkasy; Material Aluminium; Type of opening Sliding; Opening direction Inwards; Overall dimensions (W x H) 2000 mm x 2100 mm	
Special features	Increased operating forces	
Result **)	Air permeability according to EN 12207:2016-12 Class: 2	Instructions for use
	Resistance to wind load according to EN 12210:2016-03 Class: B1	The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.




Class: 2

Resistance to wind load according to EN 12210:2016-03



Class: B1

ift Rosenheim
10.09.2025


Robert Kolacny, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Component Testing


Maximilian Denkl
Operating Testing Officer
Building Component Testing

Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift-Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 613-A0FD3